15 Thompson Road, East Windsor, CT 06088
worldcordsets.com · compliance@worldcordsets.com

CUSTOM BUILD — FOR QUOTATION ONLY

62019-J-072

6FT Black Standard NEMA 6-20P to IEC320 C19 20A 250V



62019-J-072

Configuration generated by customer. Pricing valid 30 days from the date below. Specifications are subject to engineering review prior to production. To convert this datasheet into a formal quote, contact **sales@worldcordsets.com**.

Reopen this configuration
Scan to revisit the live builder with this cord pre-loaded.
Or visit **worldcordsets.com/configurator** and paste the share link from your purchase manager.

Specifications

SKU	62019-J-072
Plug	NEMA 6-20P
Connector	IEC C19
Cordage	12AWG/3C SJT
Length	6 M *(6.00 m)*
Wire color	Black
Electrical rating	20A / 250V
Lead time	2 days from order
Approvals	*Pending engineering review — assigned at order acceptance*
HTS Code	8544.42.9090

Configuration generated at Nov 14, 2026 at 3:27 pm. This datasheet is not a Certificate of Conformance — custom builds receive a per-order CoC at production sign-off — and is not a contract. Specifications subject to engineering review prior to production.

15 Thompson Road, East Windsor, CT 06088
worldcordsets.com · compliance@worldcordsets.com

UL listing reference

Compliance evidence summary for the cord families documented in this pack. The listing below is the public-record proof of UL recognition for the cordage + connector pair; it is reproduced here verbatim for the convenience of customer quality / engineering review.

UL PRODUCT IQ — RECOGNIZED COMPONENT

ELBZ7.E210037

Verify the live listing at **https://iq.ulprospector.com** using the file number above.

UL Product iQ® is a registered service mark of UL LLC. Reproduction in customer-facing documents is permitted under the recognized-component agreement on file with our supplier.

Compliance summary

UL recognized component	ELBZ7.E210037 *(MSL Taiwan — primary supplier)*
Listing scope	Power supply cords & cord sets; flexible cord molded plug-end sets; cord-end fittings. Covers the cordage + connector pair for this family.
Approvals	cULus
Certifications	RoHS, REACH, TSCA
Origin	TBD
HTS Code	8544.42.9090

This page is a reference summary of the recognized-component listing only. The full Certificate of Conformance for this family is included earlier in this document pack and is signed under delegated Quality Assurance authority. For order-time compliance documentation, contact compliance@worldcordsets.com.